

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Beverly Hills Mutual WC

Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on February 3, 2026 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Required Language	Date Correction is Required	Steps We Are Taking
R525 - Supplier was not properly monitoring and recording residual disinfectant concentration.	Disinfectant residual serves as one of the final barriers to protect public health. Lack of an adequate disinfectant residual may increase the likelihood that disease-causing organisms are present.	4/16/2026	The entry point chlorine is monitored weekly as required and a minimum chlorine residual will be kept above 0.2 mg/L. CDPHE will be provided with 5 weeks of chlorine residual at the entry point to resolve this violation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the inspection it was identified that we did not complete all

monitoring/testing, were not monitoring correctly, or were monitoring at an inappropriate location. Therefore we cannot be sure of the drinking water quality during that time.

What does this mean? What should I do?

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving the problem by **April 16, 2026**. For more information, please contact **Gene Crandall** at **GMCrandall@aol.com** or **303-887-7448**, or **7830 N Coventry Drive Castle Rock, CO 80108**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: Beverly Hills Mutual WC - CO0118001
Date distributed: **March 31st, 2026**

Three monitoring violations occurred over a three year period. The specific monitoring violations referenced by this notice occurred during the following three time frames:

From November 28, 2023 through December 1, 2023

From April 26, 2024 through April 30, 2024

From July 15, 2024 through July 18, 2024